



Gas safety check list

This check list is for use by catering vendors and authorised persons and should form a part of the catering vendor's safety plan.

Event name:

Vendor's name:

Stall number:

Mobile catering vehicle compliance number:

Vendor's signature:

Date:

Appliances	Yes	No	Action if No
Can proof of certification be provided for each appliance?	☐	☐	
Are all gas appliances in good working order?	☐	☐	
Are all appliance taps and knobs clearly marked and in good condition?	☐	☐	
Are all portable gas appliances correctly secured and placed on non-combustible surfaces?	☐	☐	
Are all portable and installed gas appliances adequately ventilated according to the requirements of this Code of Practice?	☐	☐	
Are all LP Gas cylinders in use located outside or in accordance with Table 1?	☐	☐	
Are appliances marked for use at pressures not exceeding 3kPa?	☐	☐	

Hoses and consumer piping	Yes	No	Action if No
Are all hoses in use in good condition?	☐	☐	
Are all hoses in use protected from accidental damage?	☐	☐	
Are all hoses in use less than 3m in length?	☐	☐	
Is the consumer piping in good condition?	☐	☐	
Regulators	Yes	No	Action if No
Are all regulators in good condition?	☐	☐	
Are all regulators in use protected from accidental damage?	☐	☐	
Cylinders	Yes	No	Action if No
Are all cylinders to be used in good condition?	☐	☐	
Have all cylinder connections been checked for leaks?	☐	☐	
Are all cylinders to be used stable and correctly secured?	☐	☐	
Are all cylinders to be used installed on a firm, level, non-combustible base, and not resting on soil?	☐	☐	
Is the floor or base on which cylinders are installed, constructed so that water cannot gather within any enclosure or recess?	☐	☐	
Are all cylinders to be used located away from flammable materials and ignition sources?	☐	☐	
Are walkways and egress routes clear of obstructions including LP Gas cylinders?	☐	☐	
Is the quantity of cylinders to be used correct for the structure type?	☐	☐	
Is the size of cylinders to be used appropriate for the structure type?	☐	☐	
Are all cylinders to be used within their test date period?	☐	☐	